

THE CODE OF ORDINANCES OF THE CITY OF RED LAKE FALLS, MINNESOTA 1987, IS HEREBY AMENDED MARCH 11, 2013 BY ADDING A SECTION TO BE NUMBERED 403.11, WHICH SECTION READS AS FOLLOWS:

Section 403.11 USE OF SUMP PUMPS AND DISCHARGE OF STORM WATER, GROUND WATER AND SURFACE WATER INTO SANITARY SEWER SYSTEM

1. Prohibited Water.

a) It shall be unlawful for any owner, occupant or use of any premises to direct into or allow any storm water, surface water, ground water, well water or water from industrial or commercial air conditioning systems to drain into the sanitary sewer system of the City of Red Lake Falls. No rain spout, or other form of surface drainage and no foundation drainage or sump pump shall be connected or discharged into any sanitary sewer.

2. Sump, Pump and Rigid Pipe Required.

a) New Subdivisions: All Construction. A sump, pump and rigid pipe discharge connection to the outside shall be required for all construction in new subdivisions when it is determined necessary by the Public Works Supervisor or his designee to protect sanitary sewer infiltration. The Public Works Supervisor or his assigns shall conduct his analysis and make his determination of soil conditions on a subdivision basis. The sump, pump and rigid pipe discharge requirement will apply to all units constructed within a specific subdivision.

b) Existing Subdivisions: New Construction. Any new construction in a subdivision platted prior to the effective date of this ordinance shall be examined by the Public Works Supervisor or his assigns when the footing inspection is made. At that time the Public Works Supervisor or his assigns will determine, based upon excavated soils, whether the sump, pump and rigid connection are required. Should the building owner choose the option of installing a sump, pump and rigid connection where they are not required, they shall be installed in accordance with 3(a) and 3(b) below.

c) Existing Subdivisions, Existing Construction. Any existing construction in a subdivision platted prior to the effective date of this ordinance in which a sump and pump have been or will be installed, shall be required to install a rigid pipe connection discharge in accordance with 3(b) below. It shall be unlawful to maintain any connection with the sanitary sewer carrying roof water, ground water, surface water or any other natural precipitation after the effective date of this ordinance.

THE CODE OF ORDINANCES OF THE CITY OF RED LAKE FALLS, MINNESOTA IS HEREBY AMENDED NOVEMBER 27, 2017, SECTION 403.11 SUMP, PUMP AND RIGID PIPE REQUIRED, D) EXCEPTIONS, TO READ AS FOLLOWS:

d) Exceptions. In certain locations where surface storm water discharge would create a safety hazard during freezing weather, connection to the sanitary sewer may be maintained from November 1st to March 31st. In no case, shall any connection to the sanitary sewer be maintained from April 1st to October 31st. Exceptions will be granted by permit on a case by case basis as determined by the Public Works Supervisor or his designee. Any property owner receiving a permit shall pay a seasonal

discharge monthly user fee established in the annual fee chart for use of the sanitary sewer system. The monthly fee shall be added to and collected with the regular monthly sewer bill of the property owner. Those sump pumps must be removed from the sanitary sewer before April 1st and a daily non-compliance fee set by the annual fee chart will be charged after April 1st for non-compliance.

3. Sump, Pump and Rigid Pipe: Method of Installation.

a) The building shall have a drain tile placed around the inside or outside perimeter of the foundation connected to a sump pit. All baseboard seepage collection systems shall be discharged to the sump pit. The sump pit shall be located at least ten (10) feet away from the inside sanitary floor drain.

b) A discharge pipe shall be installed to the outside wall of the building with rigid pipe (plastic, copper, galvanized or black pipe) one (1) inch inside diameter minimum. The discharge pipe must have a check valve within one (1) foot of the floor grade and a union or other approved coupling for easy disconnection for repair or replacement. The discharge shall extend at least three (3) feet outside of the foundation wall.

c) Alternate methods of installation.

1. The discharge pipe may be connected directly to the municipal underground storm sewer system provided the discharge is at a higher elevation than the normal flow level and that an approved backflow prevention device is installed.
2. The discharge may be connected directly to the municipal curb and gutter system provided the pipe is placed under the sidewalk or boulevard and through the back of the curb and that an approved backflow prevention device is installed.
3. Any other discharge other than natural body fluids must be approved by the Public Works Supervisor or his assigns.

4. Penalties.

a) Any person found to be violating any provision of this ordinance shall be served by the City with written notice stating the nature of the violation and providing a reasonable time limit for the satisfactory correction thereof. The offender shall, within a period of sixty (60) days, permanently cease all violations.

b) Any person who shall continue any violation beyond the time limited provided shall be guilty of a misdemeanor, and on conviction thereof shall be fined in the amount not exceeding Two Hundred and no/100 Dollars (\$200.00) for each violation. Each day in which any such violation occurred shall be deemed a separate offense.

c) In the event that the owner fails to correct the situation within sixty (60) days from the date of notice, the City may correct it and collect such costs together with reasonable attorneys fees and the collection fees by suing the owner in a court of competent Jurisdiction, or in the alternative, by certifying

said costs of correction as any other special assessment upon the land from which said correction of said violation was made.

5. Validity.

All ordinances or parts of ordinances in conflict herewith are hereby repealed.

6. Powers and Authority of Inspections.

The Public Works Supervisor or his assigns and other duly authorized employees of the City bearing proper credentials and identification shall be permitted to enter all properties for the purpose of inspection, observation, measurement, sampling, and testing pertinent to discharge to the community system in accordance with the provisions of this ordinance upon one (1) day notice to occupant.